



NOTES:

- SOFT METAL PIPE FLASHING:
 - SHEET LEAD: MINIMUM OF 2 1/2 LB. PER SQUARE FOOT [12 kg/m²] OR
 - SHEET COPPER: MINIMUM 16 OZ. [5 kg/m²].
- IF USING COPPER FLASHING OVER AN IRON OR STEEL PIPE, INSERT A SEPARATOR SHEET (E.G., ASPHALT SATURATED ROOFING FELT), WRAPPED AROUND PIPE, TO SEPARATE THE COPPER FLASHING FROM DIRECT CONTACT WITH PIPE, TO REDUCE GALVANIC ACTION.
- VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES [305mm] OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING. (SEE TABLE 4.)
- NRCA SUGGESTS THAT THE TOP STRIPPING PLYS BE A HEAVY-WEIGHT POLYMER BITUMEN SHEET.